



OFFICE OF WILL COUNTY EXECUTIVE
JENNIFER BERTINO-TARRANT

Will County Office Building – 302 N Chicago Street – Joliet, Illinois 60432

Kevin Lynn
Purchasing Director

(815) 740-4712
Fax (815) 740-4604
klynn@willcountyillinois.com

BID # 2021-63
VENTILATOR FURNISH & INSTALL
WILL COUNTY D.O.T.
JOLIET, IL

ADDENDUM #1
MARCH 11, 2021

Please note, the contractor who initially installed the roofing is Malcor Roofing, 1850 Dean St., St. Charles, IL 60174

We received the following questions regarding the bid listed above:

Question # 1 Does the test & balance need to be a certified report from a 3rd party.

Answer # 1: Note M on Drawing ME-1 indicates that the TAB sub-contractor needs to be certified by either AABC or NEBB and the work must be performed in accordance with AABC Standards.

Question # 2 Also just want to confirm the roof curb for the ERV that will sit on top of the existing capped base does not need to be flashed in. The drawing does not indicate this and I don't see the need for it but I want to be sure. The curb for the duct penetrations would be the only required roofing on this project from what I see.

Answer # 2: Note on Drawing ME-1 indicates new prefabricated ERV Roof Curb set on top of existing roof curb. The existing curb is already flashed but the contractor will need to make the installation of the new curb water tight.

a. Note N and O on Drawing ME-1 indicate roofing work needs to be done to maintain existing roof warranty and the installation needs to be water tight.